

BUTTE COUNTY AIR QUALITY MANAGEMENT DISTRICT

**RULE 220 - HOLD-OPEN LATCH REQUIREMENT FOR RETAIL SERVICE STATIONS**

*(Adopted June 6, 1989; Recodified August 22, 2002)*

- 1 HOLD-OPEN LATCH REQUIREMENT FOR RETAIL SERVICE STATIONS:** All new or existing retail service stations, regardless of gasoline throughput, shall install and maintain in good working order hold-open latches on all gasoline dispensing nozzles by January 1, 1990, except where prohibited by the local fire authority.